

FACE NAIL (A MIN. OF TWO NAILS PER SIDE) AT THE FLASHING ON EACH SIDE OF POST

FLASHING IS SECURED TO SUBFLOOR WITH NAILS ON ALL SIDES

26 GAUGE GALVANIZED, FLAT METAL INSTALLED ON ALL CORNERS OF THE POST AND NAILED TO THE SUBSTRATE AND SEAL WITH SEALANT

WOOD POST

ASTM C-920 POLYURETHANE SEALANT.

ASTM C-920 POLYURETHANE SEALANT AFTER FIBERGLASS & PD RESIN

5/8" MIN. EXPOSURE 1 SHEATHING (3/4" RECOMMENDED) SLOPE 1/4" PER 12"

STRUCTURAL DESIGN (BY OTHERS)

1/8" OR 1/4" KREK TO GO IN CURB CUT AROUND POST

WOOD POST

APPLY ASTM C-920 POLYURETHANE SEALANT BEHIND FLASHING AND AT THE TOP OF THE FLASHING

APPLY ASTM C-920 POLYURETHANE SEALANT AFTER COMPLETION OF THE PLI-DEK BASE COAT AROUND BASE OF POST. PLI-DEK SYSTEM TERMINATES AT THIS POINT. GS88 TO BE COATED ON ALL VERTICAL FLASHING

1" x 4" NOTCHED WOOD TRIM AROUND PERIMETER OF BASE (OPTIONAL)

ASTM C-920 SEALANT

3/4 OZ. FIBERGLASS & PD RESIN (CONTACT PLI-DEK FOR REQUIREMENTS)

GU80 BASE COAT

2.5 GALVANIZED METAL LATH

GU80 TOP COAT

GS88 PIGMENTED SEALER

SLOPED DECK

26 GAUGE (BONDERIZED) 2-PIECE SHEET METAL SADDLE MIN. 4" LAP FULLY BEDDED IN SEALANT. (ALL 4 SIDES OF POST TO BE FLASHED)

POST CONNECTION (BY OTHERS)

DETAIL-WOOD POST FLASHING

SCALE: N.T.S.



41610 Date St., Suite 104 * Murrieta, CA. 92562
Phone: 800.364.0287 * Fax: 951.834.9555
WWW.PLIIDEK.COM

These waterproofing procedures are not to be used for permit and should be reviewed by the project architect. The waterproofing procedures are not complete plans or specifications and a professional design professional should be contacted prior to performing major waterproofing and repairs.

System: Pli-Dek System
ICC-ES ESR-2097
Detail: WOOD POST FLASHING

Job:
Date: 05-3-2013
Dwn: H.K

Drawing Number:
PD-19A