

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 8110-2327:0500

CATEGORY: Decking For Wildland Urban Interface (W.U.I)

LISTEE: ICP Construction, 150 Dascomb Rd, Andover, MA 01810
Contact: Adrienne Malek (951) 837-5959
Email: amalek@icpgroup.com

DESIGN: Pli-Dek ESR-2097 Walking Deck System. Product consists of a polymer modified cementitious coating covering 2.5 lbs/sq. yd. of galvanized metal lath over a minimum 5/8" plywood substrate.

Refer to manufacturer's installation instructions and product data sheets.

RATING: Tested in accordance with ASTM E84 with an additional 20-minute period

Class A
Flame Spread Index: 0
Smoke Developed Index: 5
Max Flame Front: 8.5 feet

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and SFM label.

APPROVAL: Listed as decking material for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details.

12-02-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **December 02, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division