

**DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION****Section: 07 18 13—Pedestrian Traffic Coatings****REPORT HOLDER:**

PLI-DEK LLC

**EVALUATION SUBJECT:****PLI-DEK AND CON-DEK WALKING DECK AND ROOF COVERING SYSTEMS****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Pli-Dek and Con-Dek Walking Deck and Roof Covering Systems, described in ICC-ES evaluation report [ESR-2097](#), have also been evaluated for compliance with the codes noted below as adopted by the Los Angeles Department of Building and Safety (LADBS).

**Applicable code editions:**

- 2020 *City of Los Angeles Building Code* (LABC)
- 2020 *City of Los Angeles Residential Code* (LARC)

**2.0 CONCLUSIONS**

The Pli-Dek and Con-Dek Walking Deck and Roof Covering Systems, described in Sections 2.0 through 7.0 of the evaluation report [ESR-2097](#), comply with the LABC and the LARC, and are subjected to the conditions of use described in this supplement.

**3.0 CONDITIONS OF USE**

The Pli-Dek and Con-Dek Walking Deck and Roof Covering Systems described in this evaluation report supplement must comply with all of the following conditions:

- All applicable sections in the evaluation report [ESR-2097](#).
- The design, installation, conditions of use and identification of the Pli-Dek and Con-Dek Walking Deck and Roof Covering Systems are in accordance with the 2018 *International Building Code*® (IBC) or the 2018 *International Residential Code*® (IRC), as applicable, provisions noted in the evaluation report [ESR-2097](#).
- The design, installation and inspection are in accordance with additional requirements of LABC Chapters 15, 16 and 17 or LARC Chapter 9, as applicable.
- The installation of Pli-Dek and Con-Dek Walking Deck and Roof Covering Systems must comply with the City of Los Angeles Information Bulletin P/BC 2020-16, "Dwellings in High Wind Velocity Areas (HWA)."
- The Pli-Dek and Con-Dek Roof Covering Systems may be used in the exterior design and construction of new buildings located in a Fire Hazard Severity Zone within State Responsibility Areas or any Wildland–Urban Interface Fire Area, provided installation is in accordance with the 2018 *International Building Code*® (IBC) provisions noted in the evaluation report and the additional requirements of Sections 701A.3 and 705A of the LABC. The Pli-Dek and Con-Dek Walking Deck Systems comply with the performance requirements of ASTM E84 with a Class B flame spread rating in accordance with the Exception to Item 6 of LABC Section 709A.3 and may be used in the exterior design and construction of decking in new buildings located in a Fire Hazard Severity Zone within State Responsibility Areas or any Wildland–Urban Interface Fire Area.
- The Pli-Dek and Con-Dek Roof Covering Systems may be used in the exterior design and construction of new buildings located in a Fire Hazard Severity Zone within State Responsibility Areas or any Wildland–Urban Interface Fire Area, provided installation is in accordance with the 2018 *International Residential Code*® (IRC) provisions noted in the evaluation

report and the additional requirements of Sections R337.1.3.1 and R337.5 of the LARC. The Pli-Dek and Con-Dek Walking Deck Systems comply with the performance requirements of ASTM E84 with a Class B flame spread rating in accordance with the Exception to Item 6 of LARC Section R337.9.3 and may be used in the exterior design and construction of decking in new buildings located in a Fire Hazard Severity Zone within State Responsibility Areas or any Wildland–Urban Interface Fire Area.

This supplement expires concurrently with the evaluation report, reissued August 2020 and revised September 2020.